

SEQ Water Supply and Sewerage Design & Construction Code (SEQ WS&S D&C Code)

SEWERAGE CODE SCHEDULE OF AMENDMENTS

Amendment No. 2 – June 2016



This document contains information which is proprietary to the SEQ service providers and may not be used for purposes other than those intended without written consent from the SEQ service providers

Schedule of Amendments to Sewerage Code

(Changes from April 2016 Version 1.1 to June 2016 Version 1.2)

SEQ Sewerage Code		
Section	Clause	Change
General		
PART 0 - GLOSSARY		
PART 1 - PLANNING AND DESIGN	5.2	Reworded last paragraph from “LCC only permits property connections to DN225 sewers and for larger sewers, the connection shall be to a Maintenance Hole that will be provided with a Water Seal where directed” to “Where LCC permits property connections into sewers of DN300 or above, these must be into a Maintenance Hole, which may also require incorporation of a water seal or other odour prevention measures if so directed.”
PART 2 – PRODUCTS AND MATERIALS		
PART 3 - CONSTRUCTION	22.3.4.4	Deleted the amendment to this clause, which was to delete the clause itself, therefore, the clause has been reinstated.

Part 4 - SEQ Sewerage Standard Drawings	
Drawing Number	Change