

SEQ Water Supply and Sewerage Design & Construction Code (SEQ WS&S D&C Code)

SEWERAGE PUMPING STATION CODE SCHEDULE OF AMENDMENTS

Amendment No.3 – February 2020



This document contains information which is proprietary to the SEQ service providers and may not be used for purposes other than those intended without written consent from the SEQ service providers

Schedule of Amendments to Sewerage Pumping Station Code (Changes from January 2017 Version 1.2 to February 2020 Version 1.3)

SEQ Sewerage Pumping Station Code		
Section	Clause	Change
INTRODUCTION		
PART 1 - PLANNING AND DESIGN	5.2.1	Added 'and no allowance for soil friction' to the end of the item (c) paragraph
	11.3.2	Added new paragraph at the end of clause; "PVC rising mains that cross a road carriageway shall be provided as Ductile Iron pipes across the road carriageway and starting and finishing 1.0 meter either side of the road carriageway kerb with this pipe being provided with a cement mortar or other appropriate internal lining subject to the pipe's relationship to the pump stop HGL, refer the Clause 10.7. PE rising mains are permitted to be continuous as PE across a road carriageway."
PART 3 - CONSTRUCTION		
PART 4 - DRAWINGS		

SEQ Sewerage Pumping Station Standard Drawings	
Drawing Number	Change
SEQ-SPS-INDEX-1D	DRAWING TITLE CHANGED, REVISION NUMBERS UPDATED
SEQ-SPS-INDEX-1D	DRAWING TITLE CHANGED, REVISION NUMBERS UPDATED
SEQ-SPS-1102-1B	NOTE 3(c), 6, 9 AMENDED, NEW NOTE 10. TERM OF INLET MH USED.
SEQ-SPS-1102-2B	DRAWING NOT APPLICABLE TO CoGC
SEQ-SPS-1300-1C	ADDED NOTE 13, 14, 15, RENAMED GCCC to CoGC, ROOF SLAB REVISED, DAVIT 7 RAILS SAFE LOCATION REVISED, CLEARANCE TO VOLUTE ADDED
SEQ-SPS-1300-2D	NOTE 11,12 UPDATE, WELL WASHER LVL, BENCH HT ADD, H/WHEEL REMOVE
SEQ-SPS-1300-3D	ITEMS 9,10,18,29,30 ON SCHEDULE UPDATED, ADDED CONCRETE SLAB SURROUND, CHANGED FBE COATING TO TBP
SEQ-SPS-1300-4C	ITEM 6 OF THE TABLE UPDATED, PIT COVER REVISED. SALA' WALL MOUNT INFO REMOVED AND CHANGED FBE COATING TO TBP
SEQ-SPS-1300-5C	PLAN OF PUMP WELL AND VALVE CHAMBER UPDATED
SEQ-SPS-1300-6B	DRAWING NOT APPLICABLE TO CoGC
SEQ-SPS-1300-7B	CHANGED WET WELL CONCRETE CLASS TO SCC40
SEQ-SPS-1300-10C	AMENDED NOTE 4(a) WITH MORE DETAILS
SEQ-SPS-1300-11C	NEW ELECTRICAL CONDUITS NOTE 5 & DRAWING REFERENCES
SEQ-SPS-1301-1C	CORRECTED VENT POLE DRAWING REFERENCE
SEQ-SPS-1301-2C	CORRECTED VENT POLE DRAWING REFERENCE
SEQ-SPS-1301-3C	UPDATED NOTE S13 AND CORRECTED VENT POLE DRAWING

This document contains information which is proprietary to the SEQ service providers and may not be used for purposes other than those intended without written consent from the SEQ service providers

	REFERENCE
SEQ-SPS-1304-1D	ROTATED ORIENTATION OF POST BRACKETS
SEQ-SPS-1304-9D	SLOT AND CLEATS ROTATED 90 deg CLOCKWISE
SEQ-SPS-1304-10C	UPDATED NOTE 13
SEQ-SPS-1304-13C	UPDATED ITEM 22 DESCRIPTION
SEQ-SPS-1304-18B	NOTES UPDATED, FORMULAR ADDED, DRAWING INDEX TABLE AMENDED.
SEQ-SPS-1304-19B	NEW NOTE 5.
SEQ-SPS-1304-20B	NEW NOTE 5
SEQ-SPS-1304-21B	DELETED NOTES 3, 4 & 5. AMENDED DRAWING TITLE. DRAFTING IMPROVED.
SEQ-SPS-1304-22B	OLD NOTE 9 DELETED. DRAWING TITLE AMENDED. DRAFTING IMPROVED.
SEQ-SPS-1304-23B	DRAWING TITLE AMENDED. DRAFTING IMPROVED
SEQ-SPS-1304-24B	NEW SHEET SHOWING WET WELL COVER WITH SAFETY GRATE
SEQ-SPS-1304-25B	OLD NOTE 3 DELETED. DRAWING TITLE AMENDED. OLD SHEET 7 USED.
SEQ-SPS-1304-26B	DETAILS, SECTIONS AND NOTES FOR HANDRAILS DELETED AND AMENDED.
SEQ-SPS-1304-27B	NEW CENTER STANCHION AND BASE PLATE. NOTES 5&6 AMENDED.
SEQ-SPS-1304-28B	NEW DETAILS ADDED. DRAFTING IMPROVED.
SEQ-SPS-1304-29B	DETAILS AMENDED. NEW DETAILS ADDED. DRAFTING IMPROVED.
SEQ-SPS-1305-2B	ROTATED LOCKING PIN 90 deg, HANDLE REVISED
SEQ-SPS-1305-4B	REVISED TYPE 'B' BRACKET DETAIL. NEW NOTE 7.
SEQ-SPS-1308-1B	AMENDED NOTES G5 & DRAWING REFERENCES, NEW NOTES G8, G9 & G10.
SEQ-SPS-1400-1C	CORRECTED VENT POLE DRAWING REFERENCE IN NOTE G13
SEQ-SPS-1401-2C	MINOR DRAFTING IMPROVEMENT
SEQ-SPS-1405-2C	CLARIFIED THE USE OF PVC PIPES. MINOR CHANGES
SEQ-SPS-1406-2B	UPDATED NOTE 5 & 20; SHOWED CORROSION PROTECTION ON RETIC MH
SEQ-SPS-1406-3B	UPDATED NOTE 5 & 19; SHOWED CORROSION PROTECTION ON RETIC MH
SEQ-SPS-1406-4B	UPDATED NOTE 5 & 21; SHOWED CORROSION PROTECTION ON RETIC MH
SEQ-SPS-1508-2D	AMENDED DRAWING REFERENCES FOR CLARIFICATION. NEW NOTE 6.
SEQ-SPS-1602-1C	AMENDED NOTES 3, 4, 6 AND DRAWING REFERENCES. DRAFING IMPROVEMENT
SEQ-SPS-1606-1B	DELETED OLD NOTES 1, 2 & 3. NEW COMPOSITE COVER. AMENDED REFERENCES
SEQ-SPS-1608-1B	UPDATED TOP SLAB THICKNESS NOTE ON GA SECTIONAL ELEVATION